

T E S T C E R T I F I C A T E

PT-23-12-20-16

Product: Kaindl Decor Board P3/E0
Melamine faced boards for interior use under dry conditions
acc. to EN 14322:2021

Client: M. KAINDL GmbH, Kaindlstrasse 2, 5071 Wals/Salzburg, Austria

Order: Testing of formaldehyde emission acc. to EN 16516 and JIS A 1460

Basis: Test Report No. 2523001/7/W of 20 Nov 2023
Test Report No. 2118037-W-P3/E0-13/20-2023 of 14 Dec 2023


Test Result:

Characteristic	Requirement
Formaldehyde emission acc. to EN 16516 (ChemVerbotsV)	≤ 0,1 ppm
Formaldehyde emission acc. to JIS A 1460 (desiccator)	Class F****


Kaindl Decor Boards P3/E0 are subject to a contractually specified inspection of the production and on laboratory and comparative tests.
The formaldehyde emission is below the max. permissible requirement acc. to the German Chemicals Prohibition Ordinance (ChemVerbotsV), valid from 1 Jan 2020.
The formaldehyde emission acc. to JIS A 1460 complies to the requirement to Class F****.

Validity: 31 Dec 2024

Dresden, 20 December 2023


Head of laboratory




Engineer in charge